

CARACTERISTICI TABLOU

BENEFICIAR
PRIMARIA ICLOD

INSTALATIE ELECTRICA AMONTE

TENSIUNE [V] 400 FRECV [Hz] 50

CURENT NOMINAL TABLOU [A]

CURENT PREZUMAT DE SCURTCIRCUIT [kA] 5

TRATARE NEUTRU TNS

CALIBRU SIST BARE

In [A] I_{sc} [kA]

STRUCTURA

CLASA DE IZOLATIE IP

COMANDA DE MUNCĂ



TABLOU
TEG

STANDARDE DE REFERINTA

INTRERUPTOARE IN CARCASA TURNATA ☒ — SR EN 60947-2

INTRERUPTOARE MINIATURA ☒ — SR EN 60947-2

☐ — SR EN 60898-1

STRUCTURA ☒ — IEC EN 61439-1

☐



Handwritten signature



ADD TECH SRL

mun. Cluj-Napoca, Calea Dorobanți, nr. 21 Jud. Cluj
e-mail: andres.dana.maria@gmail.com

● LINIE PUNCT

Cluj-Napoca, Str. Alexandru Vlahuta, Nr. 1, et. 8, Jud. Cluj
e-mail: arh.corina.moldovan@gmail.com
tel: 0757.796.706

BENEFICIARI:

COMUNA ICLOD

PR. NR.
90/2023

SPECIFICATIE

NUME

SEMNTURA

SCARA
1:50

**AMENAJARE VESTIARE VECHI
BAZA SPORTIVA ICLOD ARENA**
com. ICLOD, loc. Iclod, str. GARII, nr. 52, jud. Cluj

FAZA
P.T.

SEF PROIECT

arh. Moldovan Corina

PROIECTAT

ing. Kontos Florina

DATA
01.2023

**INSTALATII ELECTRICE
SCHEMA MONOFILARA TE G(1/5)**

PLANSA
NR. IE04

DESENAT

ing. Kontos Florina